



Certificate of Product Approval

Licensee:

Cavicel S.p.A.

via Caduti del Lavoro 18A
Piolto, Milan, 20096, Italy

Factory:

via Caduti del Lavoro 18A
Piolto, Milan, 20096, Italy

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

Origin Mark:

FIRECEL SR 114E

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 18/07/2023

Date of original issue: 26/02/2016

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
21/12/2026



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2			2	1	4
2			3	1	4
2			4	1	4

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 18/07/2023

Date of original issue: 26/02/2016

Check BASEC website to verify validity.
Page 2 of 2

