



ISO 9001:2015
Certificato
n. 9125,CAVL



Assessed to
ISO 9001: 2015
Certificate nr.217



DECLARATION OF PERFORMANCE No. 0001/2017

1. Unique identification code of the product-type :
Caviced Part No. 63607- Heat detector cables – HDC 68°C
Caviced Part No. 63608- Heat detector cables – HDC 88°C
Caviced Part No. 44756- Heat detector cables – HDC 105°C
Caviced Part No. 44757- Heat detector cables – HDC 138°C
2. Intended use :
Continuous heat detector: at the rated temperature (68_88_105_138 °C) the insulation melts, permitting the conductors to short circuit and generate alarm signal.
3. Manufacturer :
Caviced S.p.A., via Caduti del lavoro 18A, 20096, Pioltello, Milan, Italy
4. Authorized representative : :
Mr. Andrea Zucchelli – QC Manager
Caviced S.p.A., via Caduti del lavoro 18A, 20096, Pioltello, Milan, Italy
5. Systems of Assessment and Verification of Constancy of Performance :
AVCP : 3
- 6a. Harmonized standards :
IEC 60332-1-2:2004 + AMD1:2015
- 6b. Notified body :
NB 0051 - IMQ S.p.A.
7. Declared performance :
Fire behavior : Eca

Signed on behalf of the manufacturer:

Andrea Zucchelli – QC Manager

Pioltello, 12th October 2018