



ISO 9001:2015  
Certificato  
n. 9125,CAVL



Assessed to  
ISO 9001: 2015  
Certificate nr.217



## DECLARATION OF PERFORMANCE No. 0074/2021

1. Unique identification code of the product-type :  
**Fire resistant, Flame retardant UNI 9795 and 9795-S**
2. Intended use :  
**Signal transmission in construction, railway systems and other works of civil engineering with the aim of limiting production and the spread of fire.**
3. Manufacturer :  
**Caviced S.p.A., via Caduti del lavoro 18A, 20096, Pioltello, Milan, Italy**
4. Authorized representative : :  
**Mr. Andrea Zucchelli – QC Manager**  
**Caviced S.p.A., via Caduti del lavoro 18A, 20096, Pioltello, Milan, Italy**
5. Systems of Assessment and Verification of Constancy of Performance :  
**AVCP : 1+**
- 6a. Harmonized standards :  
**UNI 9795, CEI 20-105, EN 13501 and EN 50575**
- 6b. Notified body :  
**NB 0051 - IMQ S.p.A.**
7. Declared performance :  
**Fire behavior : Cca-s1b,d1,a1**

Signed on behalf of the manufacturer:

Andrea Zucchelli – QC Manager

Pioltello, 30/04/2021