

Certificate of Product Approval

Certificate Number: 217f Issue: 06

CAVICEL SpA

Via Caduti del Lavoro 18/A 20096 Pioltello Milan

Product(s)

Cable Types as listed below: FIRECEL SR 114H See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7629-1:2015 (Standard 30 & 60) BS 6387:2013 (Category CWZ) EN 50200:2015 (Class PH60) EN 50200:2015 Annex E (30 mins) BS 5839-1:2013 (Clause 26.2d Standard)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Karen Coull

12 October 2017

14 October 2004

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: <u>enquiries@breglobal.com</u> LPCB® is a registered trademark of the Building Research Establishment Ltd.







Appendix to Certificate No: 217f **CAVICEL SpA**

Product name						LPCB Ref. No.
FIRECEL SR 114H						217f/01
Nominal csa of conductor (mm²)	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	EN 50200 Annex E	BS 5839-1 Clause 26.2
1.0 ⁽¹⁾	2	Standard 30 ⁽⁴⁾	C, W, Z	Class PH30	30min ⁽⁵⁾	Standard ⁽⁶⁾
1.5(2)	2, 3 & 4	Standard 60 ⁽⁴⁾	C, W, Z	Class PH60 & PH120	30min ⁽⁵⁾	Standard ⁽⁶⁾
2.5(2)	2, 3 & 4	Standard 60 ⁽⁴⁾	C, W, Z	Class PH60 & PH120	30min ⁽⁵⁾	Standard ⁽⁶⁾
4.0(3)	2, 3 & 4	Standard 60 ⁽⁴⁾	C, W, Z	Class PH60 & PH120	30min ⁽⁵⁾	Standard ⁽⁶⁾

Uo/U 300/500 VV

Notes:

- 1. Solid conductor only.
- 2. Solid & Stranded conductors.
- 3. Stranded conductor only.
- 4. In meeting the requirements of BS 7629-1:2015, the FIRECEL SR 114H cables listed met the requirements of smoke density of EN 61034-2:2005+A1:2013 and achieved less than 0.5%HCI on the insulation, binder tape and outer covering when tested in accordance with EN 60754-1:2014.
- 5. The duration of 30 min when tested in accordance with EN 50200:2015 Annex E is achieved by 15min for the fire and impact phase and an additional 15min for the fire, impact and water phase.
- 6. The FIRECEL SR 114H cables listed conform to BS 7629-1:2015 met Class PH60 when tested in accordance with EN 50200:2015 and met the 30 min duration when tested in accordance with EN 50200:2015:Annex E and hence met the requirements for standard fire resistance cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kylinel

Karen Coull

12 October 2017

14 October 2004

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.





Issue: 06