

## Certificate of Product Approval

Certificate Number: 217n

Issue: 01

### CAVICEL S.p.A.

Via Caduti del Lavoro 18/A  
20096 Pioltello  
Milan  
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
FIRECEL SR 104

#### Standard(s) (see Appendix for details)

BS 6387:2013 CWZ  
EN 50200:2015 (Class PH120)  
EN 50200:2015 Annex E (30 mins)  
EN 61034-2:2005+A2:2020  
EN 60754-1:2014

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Piracha*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

15 April 2021  
Date of Issue

15 April 2021  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 217n CAVICEL S.p.A.

Issue: 01

Product name						LPCB Ref. No.
FIRECEL SR 104						217n/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction (excluding drain wire and earth)	BS 6387	EN 50200	EN 50200 Annex E	EN 61034-2	EN 60754-1
1.5 <sup>(1)</sup>	2, 3 & 4	C, W, Z	PH120	Complies	>60%	<0.5% HCl
2.5 <sup>(1)</sup>	2, 3 & 4	C, W, Z	PH120	Complies	>60%	<0.5% HCl
4.0 <sup>(2)</sup>	2, 3 & 4	C, W, Z	PH120	Complies	>60%	<0.5% HCl

### Uo/U 300/500V

#### Notes:

1. Solid and Stranded conductors.
2. Stranded conductor only

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Aléa*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

15 April 2021  
Date of Issue

15 April 2021  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.



**bre**